



SECTION 09 64 29

PREFINISHED ENGINEERED WIDE-PLANK FSC OAK FLOORING

General notes to the specifier:

This is a template: edit this specification carefully to suit specific project requirements.

Following guidelines established by the construction specifications institute

This specification section organizes information in three parts:

Part 1 – General: describes administrative and procedural requirements;

Part 2 – Products: describes materials, products, and accessories to be used in the project; and

Part 3 – Execution: describes how these products are to be installed.

Referenced section numbers and titles are based on *Masterformat*, 2004 edition.

This section assumes the project manual contains complete Division 1 documents including Sections 01 33 00–Submittal Procedures, 01 62 00–Product Options, 01 25 00–Substitution Procedures, 01 66 00–Product Storage and Handling Requirements, 01 74 23–Final Cleaning, 01 77 00–Closeout Procedures, and 01 78 00–Closeout Submittals. If the project manual is lacking these sections, additional information should be included under the appropriate articles herein.

Editing guide:

/ italicised paragraphs are notes to the specifier and should be deleted from final draft.

[square brackets] denote options requiring selection by the specifier- delete unused options.

_____underlined blanks indicate items that may require supplementary information.

Bold face type is used to highlight optional paragraphs and phrases that may be selected or deleted as required. Reformat bold face type when including these elements



PART 1 - GENERAL

1.1 SUMMARY

- A. Section Includes: Prefinished, [pre-stained] 3-cross-ply engineered flooring installed by the [floating method] [glue down method.] [nail or staple-down method.]

- B. Related sections:

List other specification sections dealing with work directly related to this section and for other types of flooring materials abutting the bamboo flooring

1. **01 35 14 – LEED Credit Summary.**
2. **03 30 00 – Cast-in-Place Concrete: Concrete slab substrate.**
3. **06 10 00 – Rough Carpentry: Wood subfloor.**
4. **06 20 00 – Finish Carpentry: Baseboards and associated trim not otherwise included in this section.**
5. _____ - _____.

1.2 SUBMITTALS

- A. Submit under provisions of Section 01 33 00–Submittal Procedures the following items:
1. Product Data.
 - a. Flooring: Include **natural and complete range of 12 available colors or selected custom-matched colors**, adhesive used in manufacture of flooring planks and finish data.
 - b. **Accessories.**
 - c. **Installation adhesive.**
 - d. **Installation fasteners.**
 2. Shop Drawings: Include direction of flooring, fastening method, flooring patterns and color layout, and 1:1 scale sectional details of **accessories and** transition to other flooring materials.
 3. Samples:
 - a. 12 inch (300 mm) long piece of pre-finished engineered wide-plank oak flooring material in specified stock or custom colour-matched color.
 - b. Fasteners.
 - c. **One of each specified accessory, minimum 4 inches (100 mm) long.**
 4. Quality Assurance/Control Submittals:
 - a. Qualifications: Proof of manufacturer and installer qualifications.
 - b. Test Reports: Reports for specified Physical Property Performance Requirements.
 - c. Manufacturer's Installation Instructions.
- B. Closeout Submittals: Submit under provisions of Section 01 78 00–Closeout Submittals the following items:
1. Maintenance Instructions.
 2. Letter of Warranty.



C. LEED Submittals:

1. Credit EQ 4.1: Wood flooring adhesive manufacturer's product data indicating that the adhesive used has a VOC of less than 100 (g/L less water).
2. Credit EQ 4.2: Wood flooring coating data indicating finish used has a VOC of less than 275 g/L.
3. Credit EQ 4.4: Low-Emitting Materials: Manufacturer's information showing adhesives used in flooring contain no urea formaldehyde.
4. Credit MR 7: Provide letter confirming flooring is from FSC-certified sources.

1.3 QUALITY ASSURANCE

A. Qualifications:

1. Manufacturer Qualifications
 - a. Minimum five years experience in the development, manufacture and distribution of high-performance polyurethane floor coatings and stains for wood flooring.
2. Installer Qualifications:
 - a. Minimum three years experience in hardwood flooring installation.
 - b. **Minimum three years experience in installation of hardwood flooring over radiant heating systems.**

1.4 DELIVERY, STORAGE, AND HANDLING

- A. Reference Section 01 66 00–Product Storage and Handling Requirements.
- B. Deliver engineered wide-plank oak flooring to project site in original packaging not less than 5 days prior to installation start date. Leave flooring in their sealed boxes until time of actual installation.

1.5 PROJECT/SITE CONDITIONS

*For a **radiant floor heating system** specify "5 days" in the paragraph below, otherwise specify "72 hours."*

- A. Environmental Requirements: Area to receive pre-finished wide-plank oak flooring, **and adhesive** must be maintained at normal occupancy temperature and humidity levels (40-60 R.H) for minimum [72 hours] [5 days] prior to, during and continuously following installation.
- B. Concrete sub floors: must be cured at least six weeks prior to installation.
- C. Wood sub floors: should be below 12% Moisture content (MC).

1.6 WARRANTY

FOR COMMERCIAL PROJECTS, USE WARRANTY ARTICLES A. AND B. FOR RESIDENTIAL PROJECTS USE WARRANTY ARTICLE C. ONLY.

- A. Structural Warranty: lifetime residential warranty against delamination, separation, buckling or cupping as a result of a manufacturing defect when installed and maintained in accordance with manufacturer's installation instructions.



- c. Smoke Density: ASTM E 622: Maximum 270 in flaming mode; 330 in non-flaming mode.
- d. Compressive Strength: ASTM D 3501: Minimum 7,600 psi (52 MPa) parallel to grain; 2,600 psi (18 MPa) perpendicular to grain.
- e. Tensile Strength: ASTM D 3500: Minimum 15,300 psi (105 MPa) parallel to grain.
- f. Slip resistance (ASTM C-1028): Dry .7048, Wet .7293
- g. Abrasion Resistance: ASTM D 4060, CS-17 Taber abrasive wheels: Final wear-through: Minimum 12,600 cycles.
- h. Moisture Content: ASTM D 4442, Oven Dry Method: 5.47 percent average.

B. Adhesive: [Glue-down method: One-part moisture-cured urethane premium wood floor adhesive (such as Bostik's Best).] [Floating method: PVA wood adhesive.]

C. Fasteners:

- 1. 1-1/2 Inch (38 mm) Thick Sub floor: 2 inch (50 mm) nails or staples.
- 2. 3/4 Inch (19 mm) Thick Sub floor: 1-1/2 inch (38 mm) nails or staples.
- 3. 1-inch (25 m) Thick Plywood Sub floor Over Concrete: 1-1/4 inch (32 mm) nails or staples.

2.3 ACCESSORIES

A. Sub floor filler: Portland cement-based as recommended by flooring manufacturer.

Insert accessories such as baseboards, transition strips, and thresholds here. Coordinate installation of transition strips to other flooring materials and finished floor heights, if applicable, and determine which flooring installer should provide transition materials.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine substrates upon which engineered wide-plank oak flooring will be installed.
 - 1. Verify that sub floor is structurally sound, clean, dry, and free of contaminants that would interfere with bonding of the flooring adhesive (such as concrete curing compounds, waxes or oils).
 - 2. In wood frame structures, do not begin installation of flooring until the moisture content of wood subfloors is at a maximum of 12% and within 4% of the moisture content of the flooring material.

Following three paragraphs apply only to bamboo flooring installed over concrete substrates.

- 3. Test concrete floors for moisture vapor emission using a Calcium Chloride test. Do not install flooring if vapor pressure exceeds 3 lbs per 1,000 square feet (15 g per m²) in 24 hours.
 - 4. Test alkalinity of the concrete slab to confirm it is within adhesive manufacturer's acceptable range.
 - 5. Document test results and mark all test location(s) on As-Built Drawings.
- B. Verify that HVAC system is operating and maintaining occupancy level temperature and humidity conditions.



- C. Report unsatisfactory conditions to Architect and/or General Contractor and correct before proceeding.

3.2 PREPARATION

- A. Do not acclimatize as with conventional hardwood flooring. Leave engineered wide-plank oak flooring in their sealed boxes until time of actual installation.
- B. Grind and fill sub floor using methods and materials appropriate to the sub floor construction to eliminate humps and depressions exceeding 1/8 (3 mm) inch in 6 feet (1830 mm).
- C. Clean surfaces thoroughly prior to installation.

3.3 INSTALLATION

Under normal installation conditions, the manufacturer's installation instructions are sufficient. Unusual or unique site or design conditions may demand supplementary information in this article.

- A. Engineered wide-plank oak Flooring: Install in accordance with manufacturer's complete installation instructions by [nailing or stapling to substrate] [gluing to substrate]. Details below are a summary only.
- B. Lay flooring in the direction(s)/pattern(s) as shown on Drawings.
- C. For a blended appearance select pieces randomly from several boxes.
- D. Allow 3/8-inch (10 mm) space for expansion and movement of flooring at walls and permanent obstructions.

| Include the following paragraphs if floating installation method is used.

- E. Lay 6-mil polyethylene vapor barrier on substrate. Lap edges and ends a minimum of 8" and tape seal.
- F. Apply thin glue bead to the top inside edge of groove at side and end of each board. Press boards firmly together, using tapping block as necessary. Tape glued boards together at side and end seams. Allow first two rows to set and dry before continuing to lay subsequent rows in the same fashion.

| Include the following paragraphs if adhesive installation method is used.

- G. Use the "wet lay" or "walk-on-work" installation method as specified by the adhesive manufacturer. Use only adhesive recommended by flooring manufacturer. Adhere bamboo flooring strips without gaps. Ensure that each floor strip is completely adhered to substrate.
- H. Adhere flooring planks without gaps. Ensure that each floor strip is completely adhered to substrate.



I. Immediately remove excess adhesive from pre-finished surface of flooring.

| Include the following paragraphs if nailed or stapled installation method is used.

J. Lay engineered wide-plank oak flooring over wood sub floor parallel with length of room.

K. Blind [staple][nail] flooring to sub floor with power driver. Space fasteners at 6-10" (152-254 mm) and 2" (51mm) from end of boards. Stagger end joints from row to row by a minimum of 12" (305mm).

L. Accessories: Install using methods appropriate to the accessory and flooring system.

3.4 CLEANING

A. Reference Section 01 74 23–Cleaning.

B. Follow manufacturer's recommended maintenance instructions.

3.5 PROTECTION

A. Repair or replace defective or damaged work as directed by the Architect. All chipped, scratched or otherwise damaged or defective work will be repaired or replaced. All repairs shall be undetectable. Use manufacturer-supplied touch up stain if required.

B. Cover and protect completed engineered wide-plank oak flooring from further construction traffic with heavy Kraft-paper or other suitable covering. Do not use non-breathable sheet or film that could cause condensation to form. Maintain covering throughout remainder of construction period.

END OF SECTION

This specification was last updated in September 2008.
The most recent revision of this document is available at www.durodesign.com